

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 6996 Main	on ID: 6996 Main Street: MCALLISTER_DR			Cross Street: CRENSHAW_CT			
ADA ID: 58BF19BBFA7F Ramp Type: Perp		Initial Pass/Fail: Fail Overall Compliance: No			o Severity Score:	33.75	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance					
	Possible Solutions:	Co	mpliance Desc	ription Data	Comp	liance Description	Data
A line as the	Remove & Replace Entire Ramp	. N/A	Ramp Leng	th (in) 27.0	No	Ramp Slope (%)	9.1
The state of the second second second	and the second s	No	Ramp Width	n (in) <b>46.0</b>	No	Ramp XSlope (%)	6.2
		N/A	Flare Type I	LT N/A	N/A	Flare Type RT	N/A
		N/A	Flare Slope	LT (%) N/A	N/A	Flare Slope RT (%)	N/A
为"····································		N/A	Flare Trave	rsable LT? N/A	N/A	Flare Traversable RT?	N/A
	N. C.	N/A	Landing Ler	ngth (in) N/A	N/A	DWS Provided?	N/A
MOALUSTER_DR	Surveyor Notes:	N/A	Landing Wid	dth (in) N/A	N/A	DWS Contrast?	N/A
the the the test of te	N/A	N/A	Landing Slo	pe (%) N/A	N/A	DWS Length (in)	N/A
The statement of the st	1	N/A	Landing X S	Slope (%) N/A	N/A	DWS Full Width?	N/A
		N/A	Landing Cu	rb? (Y/N) N/A	N/A	DWS Offset (in)	N/A
		N/A	Shared Lan	ding? N/A			
	PROW/ADA:	N/A	Gutter Pond	ling? N/A	N/A	Gutter Slope (%)	N/A
	Not Found, R304.5.1, R304.2.2,	N/A	Gutter Lip H	It (in) N/A	N/A	Gutter X Slope (%)	N/A
10 IN 10 IN	R304.5.3	N/A	Painted X W	/alk1? No	N/A	Painted X Walk2?	N/A
			X Walk 1 Di	rection To W		X Walk 2 Direction	N/A
		N/A	X Walk 1 W	idth (in) N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name CRENSHAW	 2T		X Walk 1 Sl	ope (%) 1.9		X Walk 2 Slope (%)	N/A
Stop Condition-Street 2 StopSi	jn		X Walk 1 X			X Walk 2 X Slope (%)	N/A
Street 2 Name	Ά	N/A	Ramp inside	e XWalk1? N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	Ά		Road Slope	(%) N/A	N/A	Clear Space?	N/A
			Road X Slop	. ,	N/A	Clear Space to XWalk (in)	N/A
		N/A			N/A	Storm Grate/Utility Hazard?	N/A
	Total Cost: \$ 1	1850.00	Obstruction			Storm Grate/Utility Type	
				N/A			N/A

Yes Surface Condition? (G/P)

Good

