


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 47903	Main Street: SPUR_RANCH_RD	Cross Street: ROUND_ROCK_RD	Location:	N
ADA ID: 5980097CCE9E	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 21.25

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance						
 <div>Street 1 Name<div>SPUR RANCH RD</div></div> <div>Stop Condition-Street 2<div>None</div></div> <div>Street 2 Name<div>ROUND ROCK RD</div></div> <div>Stop Condition-Street 1<div>StopSign</div></div>	Possible Solutions: Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		Compliance	Description	Data	Compliance	Description	Data
			N/A	Ramp Length (in)	46.0	No	Ramp Slope (%)	8.5
			No	Ramp Width (in)	42.5	Yes	Ramp XSlope (%)	1.8
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
		N/A	Shared Landing?	N/A				
		N/A	Gutter Ponding?	N/A	N/A	N/A	Gutter Slope (%)	N/A
		N/A	Gutter Lip Ht (in)	N/A	N/A	N/A	Gutter X Slope (%)	N/A
		N/A	Painted X Walk1?	No	N/A	N/A	Painted X Walk2?	No
			X Walk 1 Direction	To SW			X Walk 2 Direction	To SE
		N/A	X Walk 1 Width (in)	N/A	N/A	N/A	X Walk 2 Width (in)	N/A
			X Walk 1 Slope (%)	0.9			X Walk 2 Slope (%)	0.6
			X Walk 1 X Slope (%)	0.9			X Walk 2 X Slope (%)	2.1
		N/A	Ramp inside XWalk1?	N/A	N/A	N/A	Ramp inside XWalk2?	N/A
			Road Slope (%)	1.5	N/A	N/A	Clear Space?	N/A
			Road X Slope (%)	2.7	N/A	N/A	Clear Space to XWalk (in)	N/A
		N/A	Any Obstructions?	N/A	N/A	N/A	Storm Grate/Utility Hazard?	N/A
			Obstruction Type				Storm Grate/Utility Type	
				N/A				N/A
					Yes		Surface Condition? (G/P)	Good
		Total Cost:	\$	3200.00				

Street 1 Name	SPUR RANCH RD
Stop Condition-Street 2	None
Street 2 Name	ROUND ROCK RD
Stop Condition-Street 1	StopSign

