

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 9925	Main Street: TENNYSON_DR	Cross Street: TUCKASEEGEE_RD	Location:	E
ADA ID: 5B40BD976903	Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score: 10
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance		



Possible Solutions:

**Remove & Replace Entire Ramp.
Remove & Replace Gutter.**

Surveyor Notes:

N/A

PROW/ADA:

**R304.2.2-Perp, R304.3.2-Para,
R304.5.3, R304.2.3, R305.2, R302.7,
R304.5.4**

Total Cost: \$ 2350.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	83.0	Yes	Grade Break?	Yes
Yes	Ramp Width (in)	48.0	Yes	Grade Break Slope (%)	0.9
Yes	Ramp Slope (%)	4.3	No	Grade Break XSlope (%)	2.9
Yes	Ramp XSlope (%)	0.8			
Yes	Flare Type LT	N/A	No	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
Yes	Landing Length (in)	64.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	67.0	Yes	DWS Contrast?	Yes
No	Landing Slope (%)	2.5	Yes	DWS Length (in)	25.0
Yes	Landing X Slope (%)	0.8	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset LT (in)	43.0
N/A	Shared Landing?	No	No	DWS Offset RT (in)	5.0
No	Gutter Ponding?	Yes	No	Gutter Slope (%)	7.9
Yes	Gutter Lip Ht (in)	0.0	No	Gutter X Slope (%)	2.3
N/A	Painted X Walk1?	No		Road Slope (%)	4.9
	X Walk 1 Direction	To W		Road X Slope (%)	0.9
	X Walk 1 Width (in)	N/A		Clear Space?	Yes
	X Walk 1 Slope (%)	4.9	N/A	Clear Space to XWalk (in)	N/A
	X Walk 1 X Slope (%)	0.9	Yes	Storm Grate/Utility Hazard?	No
N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type	
Yes	Any Obstructions?	No			N/A
	Obstruction Type		Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	1.0

