cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 20059 Main Street: BELKNAP_RD Cross Street: FOXCROFT_RD							Location:	NE
ADA ID: 5CCF024F4671 Ramp Type: PerpDiag		initial Pa	nitial Pass/Fail: Fail Overall Compliance: No					10
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
ELENNAP-RD ELENNAP-RD E	Possible Solutions:		Compliance Description			Data Compliance Description		
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.	ith	N/A	Ramp Length (in)	96.0	Yes	Ramp Slope (%)	6.1
			No	Ramp Width (in)	45.0	No	Ramp XSlope (%)	3.3
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
	Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
	N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A			
	PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
	Not Found, R304.5.1, R304.5.3		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
	,,,		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
				X Walk 1 Direction	To W		X Walk 2 Direction	To S
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name FOXCROFT RD				X Walk 1 Slope (%)	6.6		X Walk 2 Slope (%)	7.0
Stop Condition-Street 2 None				X Walk 1 X Slope (%)	6.5		X Walk 2 X Slope (%)	4.9
Street 2 Name BELKNAP RD			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1 StopSign				Road Slope (%)	4.0	N/A	Clear Space?	N/A
				Road X Slope (%)	9.4	N/A	Clear Space to XWalk (in)	N/A
			N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Total Cost: \$ 320	00.00		Obstruction Type			Storm Grate/Utility Type	
					N/A			N/A

Yes Surface Condition? (G/P)

Good

