

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 42379	Main Street: CALLABRIDGE_CT	Cross Street: MT_HOLLY-HUNTERSVILLE_RD	Location: NW
ADA ID: 5CDF85BC62A8	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No Severity Score: 7.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

**Remove & Replace Entire Ramp.
Remove & Replace Gutter.**

Surveyor Notes:

N/A

PROW/ADA:

**R304.5.3, R304.2.1, R304.2.2-Perp,
R304.3.2-Para, R304.2.3, R305.2,
R304.5.4**

Total Cost: \$ 2600.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	49.0	Yes	Ramp Slope (%)	6.7
Yes	Ramp Width (in)	53.5	No	Ramp XSlope (%)	4.3
N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	3.7	No	Flare Slope RT (%)	11.3
N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
No	Landing Length (in)	46.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	53.0	Yes	DWS Contrast?	Yes
No	Landing Slope (%)	6.3	Yes	DWS Length (in)	24.0
No	Landing X Slope (%)	3.1	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	7.5
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	No	Gutter Slope (%)	5.8
Yes	Gutter Lip Ht (in)	0.0	No	Gutter X Slope (%)	4.3
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To SW		X Walk 2 Direction	N/A
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	3.2		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	0.6		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A	N/A	Clear Space?	Yes
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good

Street 1 Name CALLABRIDGE CT
Stop Condition-Street 2 Signal
Street 2 Name N/A
Stop Condition-Street 1 N/A

