cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 9974 Ma	Main Street: EDGEWOOD_RD		Cross Street: TUCKASEEGEE_RD			Location:	E	
ADA ID: 5EDA1624F7A4 Ra	Ramp Type: PerpDiag		itial Pass/Fail: Fail Overall Compliance			o Severity Score:	72.5	
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
E E E	Possible Solutions:	Com	Compliance Description Dat		a Compliance Description		Data	
	Remove & Replace Curb Ramp W	/ith N/A	Ramp Length (in)	63.0	No	Ramp Slope (%)	9.9	
	Two New Directional Ramps or Equivalent.	No	Ramp Width (in)	29.0	No	Ramp XSlope (%)	7.2	
		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
		N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
		N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
		N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
	Surveyor Notes:	N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
	N/A	N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
		N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
		N/A	Shared Landing?	N/A				
	PROW/ADA:	N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
	Not Found, R304.5.1, R304.2.2,	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
	R304.5.3	N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	Yes	
			X Walk 1 Direction	To NW		X Walk 2 Direction	To SW	
		N/A	X Walk 1 Width (in)	106.0	N/A	X Walk 2 Width (in)	110.0	
Street 1 Name EDGEWOO	D RD		X Walk 1 Slope (%)	0.4		X Walk 2 Slope (%)	7.5	
Stop Condition-Street 2 S	Signal		X Walk 1 X Slope (%)	6.6		X Walk 2 X Slope (%)	1.2	
Street 2 Name TUCKASEEGE	E RD	N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	Yes	
Stop Condition-Street 1 S	Signal		Road Slope (%)	5.2	N/A	Clear Space?	N/A	
			Road X Slope (%)	6.6	N/A	Clear Space to XWalk (in)	N/A	
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
	Total Cost: \$ 32	200.00	Obstruction Type			Storm Grate/Utility Type		
				N/A			N/A	

s Surface Condition? (G/P)

Good

