


Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 21410	Main Street: LANDMARK_DR	Cross Street: SARDIS_LN	Location: S
ADA ID: 5F13A9554682	Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 7.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance			
	Possible Solutions:		Compliance	Description	Data	
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	88.0	No
	Remove & Replace Gutter.		Yes	Ramp Width (in)	57.0	N/A
			Yes	Ramp Slope (%)	8.1	N/A
			Yes	Ramp XSlope (%)	1.6	
			Yes	Flare Type LT	N/A	No
			N/A	Flare Slope LT (%)	N/A	N/A
			N/A	Flare Traversable LT?	No	N/A
			No	Landing Length (in)	42.0	Yes
			Yes	Landing Width (in)	62.0	Yes
			No	Landing Slope (%)	3.5	Yes
			Yes	Landing X Slope (%)	0.1	No
			N/A	Landing Curb? (Y/N)	N/A	Yes
			N/A	Shared Landing?	No	No
			Yes	Gutter Ponding?	No	Yes
			Yes	Gutter Lip Ht (in)	0.0	No
			N/A	Painted X Walk1?	No	
				X Walk 1 Direction	To NE	
				X Walk 1 Width (in)	N/A	
				X Walk 1 Slope (%)	0.4	N/A
				X Walk 1 X Slope (%)	2.9	Yes
Surveyor Notes: N/A			N/A	Ramp inside XWalk1?	N/A	
			Yes	Any Obstructions?	No	N/A
Total Cost:		\$ 2350.00		Obstruction Type		Yes
						N/A
						Yes
						Yes

Street 1 Name	LANDMARK DR
Stop Condition-Street 1	StopSign
Street 2 Name	N/A
Stop Condition-Street 2	N/A

