

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 54220	Main Street: SOUTH_REA_PARK_LN	Cross Street: SANDY_ROCK_PL	Location: SE
ADA ID: 5F1B555C9D02	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Remove & Replace Entire Ramp. Remove & Replace Gutter.					
	Surveyor Notes:		N/A					
	PROW/ADA:		Not Found, R304.5.4					
	Street 1 Name		SANDY ROCK PL					
	Stop Condition-Street 2		None					
	Street 2 Name		N/A					
	Stop Condition-Street 1		N/A					
	Total Cost:		\$ 2600.00					
			Compliance	Description	Data	Compliance	Description	Data
			N/A	Ramp Length (in)	24.0	Yes	Ramp Slope (%)	5.9
			Yes	Ramp Width (in)	96.0	Yes	Ramp XSlope (%)	1.7
			Yes	Flare Type LT	Curbed_NoWalkSurface	Yes	Flare Type RT	N/A
			Yes	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
			Yes	Landing Length (in)	72.0	Yes	DWS Provided?	Yes
			Yes	Landing Width (in)	96.0	Yes	DWS Contrast?	Yes
			Yes	Landing Slope (%)	0.7	Yes	DWS Length (in)	24.0
			Yes	Landing X Slope (%)	1.0	Yes	DWS Full Width?	Yes
			N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset (in)	0.0
			N/A	Shared Landing?	No			
			Yes	Gutter Ponding?	No	No	Gutter Slope (%)	5.4
			Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	0.7
			N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To W		X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	78.0	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	1.4		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	0.9		X Walk 2 X Slope (%)	N/A
			Yes	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	N/A	N/A	Clear Space?	Yes
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
			Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
				Obstruction Type			Storm Grate/Utility Type	
					N/A			N/A
						Yes	Surface Condition? (G/P)	Good

Street 1 Name	SANDY ROCK PL
Stop Condition-Street 2	None
Street 2 Name	N/A
Stop Condition-Street 1	N/A

Total Cost: \$ 2600.00

