


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 9828		Main Street: KANIMBLA_DR		Cross Street: TUCKASEEGEE_RD		Location:		E											
ADA ID: 5FBA61E89858		Ramp Type: Directional1		Initial Pass/Fail: Fail		Overall Compliance: No		Severity Score: 1.25											
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance															
				Possible Solutions:		Compliance		Description		Data		Compliance		Description		Data			
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		122.0		N/A		Grade Break?		N/A		N/A	
						Yes		Ramp Width (in)		71.0		N/A		Grade Break Slope (%)		0.0		0.0	
						Yes		Ramp Slope (%)		5.5		N/A		Grade Break XSlope (%)		0.0			
						No		Ramp XSlope (%)		4.9									
						N/A		Flare Type LT		N/A		N/A		Flare Type RT		N/A			
						N/A		Flare Slope LT (%)		N/A		N/A		Flare Slope RT (%)		0.0			
						N/A		Flare Traversable LT?		N/A		N/A		Flare Traversable RT?		N/A			
						N/A		Landing Length (in)		0.0		N/A		DWS Provided?		N/A			
						N/A		Landing Width (in)		0.0		N/A		DWS Contrast?		N/A			
Surveyor Notes: N/A						N/A		Landing Slope (%)		0.0		N/A		DWS Length (in)		N/A			
						N/A		Landing X Slope (%)		0.0		N/A		DWS Full Width?		N/A			
						N/A		Landing Curb? (Y/N)		N/A		N/A		DWS Offset LT (in)		N/A			
						N/A		Shared Landing?		N/A		N/A		DWS Offset RT (in)		N/A			
						N/A		Gutter Ponding?		0.0		N/A		Gutter Slope (%)		N/A			
						N/A		Gutter Lip Ht (in)		0.0		N/A		Gutter X Slope (%)		N/A			
						N/A		Painted X Walk1?		No				Road Slope (%)		3.5			
								X Walk 1 Direction		To W				Road X Slope (%)		10.7			
								X Walk 1 Width (in)		N/A				Clear Space?		N/A			
								X Walk 1 Slope (%)		3.5		N/A		Clear Space to XWalk (in)		N/A			
PROW/ADA: R304.5.3						N/A		X Walk 1 X Slope (%)		10.7		N/A		Storm Grate/Utility Hazard?		N/A			
						N/A		Ramp inside XWalk1?		N/A				Storm Grate/Utility Type					
						N/A		Any Obstructions?		N/A						N/A			
								Obstruction Type				Yes		Surface Condition? (G/P)		Good			
										N/A		N/A		Curb Slope (%)		19.1			