cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 22560 M	Main Street: MORNING_DALE_RD Cross Street: SARDIS_RD					Location:	NW	
	amp Type: PerpDiag		nitial Pass/Fail: Fail Overall Compliance: No					
· · · · -		initial Fassi					13.75	
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:	Com	Compliance Description		ata Compliance Description		Data	
	Remove & Replace Curb Ramp V	Vith N/A	Ramp Length (in)	60.0	No	Ramp Slope (%)	9.8	
	Two New Directional Ramps or	Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	4.2	
	Equivalent.	N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
	lot.	N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
	11 A	N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
	1 Sar	N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
	Surveyor Notes:	N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
	N/A	N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
	Sale -	N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
		N/A	Shared Landing?	N/A				
	PROW/ADA:	N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
the second state	Not Found, R304.2.2, R304.5.3	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
they want	,, ,, ,, ,, ,	N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No	
	C.T.		X Walk 1 Direction	To SW		X Walk 2 Direction	To SE	
	And the second se	N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
Street 1 Name SARI	DIS RD		X Walk 1 Slope (%)	4.9		X Walk 2 Slope (%)	8.5	
Stop Condition-Street 2	None		X Walk 1 X Slope (%)	4.5		X Walk 2 X Slope (%)	0.8	
Street 2 Name MORNING DA	LE RD	N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
Stop Condition-Street 1 Sto	opSign		Road Slope (%)	4.0	N/A	Clear Space?	N/A	
			Road X Slope (%)	6.8	N/A	Clear Space to XWalk (in)	N/A	
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
	Total Cost: \$ 3	200.00	Obstruction Type			Storm Grate/Utility Type		
	•		21	N/A		, ,,	N/A	

Yes Surface Condition? (G/P) Good

