


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 15446	Main Street: BARRINGER_DR	Cross Street: BLAIRHILL_RD	Location: SE
ADA ID: 639575688843	Ramp Type: PerpDiag	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 17.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Grind Gutter Lip.		Yes	Ramp Length (in)	62.0
			Yes	Ramp Width (in)	48.0
			N/A	Flare Type LT	Sloped
			N/A	Flare Slope LT (%)	3.3
			N/A	Flare Traversable LT?	Yes
			No	Landing Length (in)	N/A
			No	Landing Width (in)	N/A
			No	Landing Slope (%)	N/A
			No	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>R304.2.1, R304.2.2-Perp, R304.3.2-Para, R304.5.3, R305.2, R302.7.2</p>			Yes	Flare Type RT	N/A
			Yes	Flare Slope RT (%)	5.9
			N/A	Flare Traversable RT?	Yes
			Yes	DWS Provided?	Yes
			Yes	DWS Contrast?	Yes
			Yes	DWS Length (in)	24.0
			Yes	DWS Full Width?	Yes
			No	DWS Offset (in)	4.0
			No	Gutter Ponding?	No
			No	Gutter Lip Ht (in)	0.5
<p>Total Cost:</p> <p>\$ 3400.00</p>			N/A	Painted X Walk1?	No
			To NE	X Walk 1 Direction	To W
			N/A	X Walk 1 Width (in)	N/A
			0.8	X Walk 1 Slope (%)	0.9
			0.2	X Walk 1 X Slope (%)	0.1
			N/A	Ramp inside XWalk1?	N/A
			0.1	Road Slope (%)	N/A
			1.2	Road X Slope (%)	N/A
			Yes	Any Obstructions?	No
				Obstruction Type	
<p>Street 1 Name</p> <p>BLAIRHILL RD</p> <p>Stop Condition-Street 2</p> <p>StopSign</p> <p>Street 2 Name</p> <p>BARRINGER DR</p> <p>Stop Condition-Street 1</p> <p>None</p>			N/A	Clear Space?	Yes
			N/A	Clear Space to XWalk (in)	N/A
			Yes	Storm Grate/Utility Hazard?	No
				Storm Grate/Utility Type	
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

