


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 14249	Main Street: E_3RD_ST	Cross Street: QUEENS_RD	Location: NW
ADA ID: 655569C3623F	Ramp Type: Perpendicular Diagonal	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 21.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		No	Ramp Length (in)	48.0
			No	Ramp Width (in)	39.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>Not Found, R304.5.1, R304.2.2</p>			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			N/A	Painted X Walk1?	Yes
				X Walk 1 Direction	To SW
			N/A	X Walk 1 Width (in)	106.0
				X Walk 1 Slope (%)	2.7
				X Walk 1 X Slope (%)	3.5
			N/A	Ramp inside XWalk1?	Yes
				Road Slope (%)	0.8
				Road X Slope (%)	3.8
			N/A	Any Obstructions?	N/A
				Obstruction Type	
Total Cost:		\$ 3200.00			
			N/A		
			Yes	Surface Condition? (G/P)	Good

