


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 54451	Main Street: KILKENNY_DR	Cross Street: BRAMBLE_CREEK_DR	Location: NW
ADA ID: 6603B7340468	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 0	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Detectable Warning System.		N/A	Ramp Length (in)	90.0	Yes	Ramp Slope (%)	7.6
			Yes	Ramp Width (in)	60.0	Yes	Ramp XSlope (%)	1.4
			N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	6.8	Yes	Flare Slope RT (%)	7.5
			N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
			Yes	Landing Length (in)	59.0	Yes	DWS Provided?	Yes
			Yes	Landing Width (in)	60.0	Yes	DWS Contrast?	Yes
			Yes	Landing Slope (%)	1.6	Yes	DWS Length (in)	24.0
			Yes	Landing X Slope (%)	1.8	Yes	DWS Full Width?	Yes
Surveyor Notes:		N/A	N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	5.5
PROW/ADA:		R305.2	N/A	Shared Landing?	No			
			Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	2.6
			Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	1.0
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To E		X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	2.8		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	1.1		X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	N/A	N/A	Clear Space?	Yes
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
			Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
				Obstruction Type			Storm Grate/Utility Type	
						N/A		N/A
						Yes	Surface Condition? (G/P)	Good
Total Cost:		\$ 800.00						
Street 1 Name			KILKENNY DR					
Stop Condition-Street 2			None					
Street 2 Name			N/A					
Stop Condition-Street 1			N/A					

Street 1 Name	KILKENNY DR
Stop Condition-Street 2	None
Street 2 Name	N/A
Stop Condition-Street 1	N/A

