



Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 15074	Main Street: MAGNOLIA_AV	Cross Street: PARK_RD	Location: SE
ADA ID: 664A0C68F60B	Ramp Type: Combination1	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length LT (in)	18.0
			Yes	Ramp Width LT (in)	56.0
			No	Ramp Slope LT (%)	11.4
			Yes	Ramp XSlope LT (%)	0.1
			N/A	Ramp Length (in)	68.0
			Yes	Ramp Width (in)	48.0
	Surveyor Notes:		N/A	Flare Type LT	N/A
	N/A		N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
	PROW/ADA:		N/A	Landing Length (in)	N/A
	Not Found, R304.5.3, R304.3.2		N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	2.0
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To N
				X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	3.0
				X Walk 1 X Slope (%)	2.6
	Total Cost:	\$ 1800.00	N/A	Ramp inside XWalk1?	N/A
				Road Slope (%)	N/A
				Road X Slope (%)	N/A
				Clear Space?	N/A
				Clear Space to XWalk (in)	N/A
				Any Obstruction?	N/A
				Obstruction Type	N/A
				Storm Grate/Utility Hazard?	N/A
				Storm Grate/Utility Type	N/A
					N/A
			Yes	Surface Condition? (G/P)	Good
				Curb Slope (%)	17.0