

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 10024504 Main Street: CRUMP_RD					Stract	N/A	Location:	NW		
Intersection ID: 10024504					Cross Street: N/A					
ADA ID: 66D888874BF0 Ramp Type: Perp			Initia	Initial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	22.5	
Codes/Mitigation Info/Possible Solution					Field Measurements/Component Compliance					
	唐· 出借 **	Possible Solutions:			Compliance Description			Data Compliance Description		
	目相推了	Remove & Re	eplace Entire Ra	mp.	N/A	Ramp Length (in)	71.0	No	Ramp Slope (%)	9.1
	副 井橋 🚽		•		No	Ramp Width (in)	47.0	No	Ramp XSlope (%)	4.7
	目前傳承	\$			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
	目目標業				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
					N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
	計算構造				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
		Surveyor Notes:			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		N/A			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
	目標				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
					N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
					N/A	Shared Landing?	N/A			
		PROW/ADA:			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
		Not Found, F	R304.5.1, R304.2	.2,	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
		R304.5.3	,	,	N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
						X Walk 1 Direction	To SW		X Walk 2 Direction	N/A
	山橋という				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name	ENTRANCE					X Walk 1 Slope (%)	0.1		X Walk 2 Slope (%)	N/A
Stop Condition-Street 2	StopSign					X Walk 1 X Slope (%)	2.3		X Walk 2 X Slope (%)	N/A
Street 2 Name	N/A				N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	N/A					Road Slope (%)	N/A	N/A	Clear Space?	N/A
						Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
					N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Total Cost:	\$	1850.00		Obstruction Type			Storm Grate/Utility Type	
							N/A			N/A

Yes Surface Condition? (G/P)

Good

