

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 10036601 Main Street: RUSHMORE DR **Cross Street: N/A** Location: **ADA ID: 6809D8CF4AC0** Ramp Type: BlendTrans2 Initial Pass/Fail: Fail **Overall Compliance: No** Severity Score: 36.25

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



RUSHMORE DR Street 1 Name Stop Condition-Street 1 None Street 2 Name Stop Condition-Street 2 StopSign Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes: N/A

PROW/ADA:

Not Found, R304.5.1, R304.5.3

N/A Total Cost:

Compliance Description		Data	Comp	liance Description	Data
N/A	Ramp Length (in)	59.0	Yes	BlendTrans Slope (%)	4.5
No	Ramp Width (in)	30.0	No	BlendTrans XSlope (%)	4.8
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To NW		X Walk 2 Direction	To SW
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	0.7		X Walk 2 Slope (%)	3.8
	X Walk 1 X Slope (%)	2.1		X Walk 2 X Slope (%)	2.1
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	2.2		Clear Space?	N/A
	Road X Slope (%)	0.1	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good


No

Curb Slope (%)

15.1







3200.00