

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 30556 Main Street: GREEN_LEA_CT Cross Street: GREENCREEK_DR Location: N

ADA ID: 6AC6C9B2A319 Ramp Type: PerpDiag Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 13.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name
Stop Condition-Street 2
Street 2 Name
G
Stop Condition-Street 1

GREEN LEA CT StopSign GREENCREEK DR None Possible Solutions:

Remove & Replace Curb Ramp With
Two New Directional Ramps or
Equivalent.

Surveyor Notes: **N/A**

PROW/ADA:

R304.2.2, R304.5.3





Total Cost:



3200.00

Comp	liance Description	Data	Comp	liance	Description	Data
N/A	Ramp Length (in)	43.0	No	Ramp	Slope (%)	8.7
Yes	Ramp Width (in)	48.0	No	Ramp	XSlope (%)	3.1
N/A	Flare Type LT	N/A	N/A	Flare	Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare	Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare	Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS	Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS	Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS	Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS	Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS	Offset (in)	N/A
N/A	Shared Landing?	N/A				
N/A	Gutter Ponding?	N/A	N/A	Gutte	r Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutte	r X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Paint	ed X Walk2?	No
	X Walk 1 Direction	To SW		X Wa	lk 2 Direction	To SE
N/A	X Walk 1 Width (in)	N/A	N/A	X Wa	lk 2 Width (in)	N/A
	X Walk 1 Slope (%)	1.3		X Wa	lk 2 Slope (%)	2.8
	X Walk 1 X Slope (%)	4.2		X Wa	lk 2 X Slope (%)	0.3
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp	inside XWalk2?	N/A
	Road Slope (%)	1.8	N/A	Clear	Space?	N/A
	Road X Slope (%)	2.6	N/A	Clear	Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm	n Grate/Utility Hazard?	N/A
	Obstruction Type			Storm	n Grate/Utility Type	
		N/A				N/A
			Yes	Surfa	ce Condition? (G/P)	Good