

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 48058 Main St	D: 48058 Main Street: FERRELL_AV		Cross Street: KEENER_RIDGE_RD			NE
ADA ID: 6B21EFE58CF6 Ramp Type: Perp		Initial Pass/Fail: Fail Overall Compliance: No			ce: No Severity Score:	10
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance				
Possible Solutions:				Compliance Description	Data	
And a fill and the second second	Remove & Replace Entire Ramp.	N/A	Ramp Length (in)	47.0	Yes Ramp Slope (%)	5.0
		No	Ramp Width (in)	47.0	No Ramp XSlope (%)	2.8
		N/A	Flare Type LT	N/A	N/A Flare Type RT	N/A
January		N/A	Flare Slope LT (%)	N/A	N/A Flare Slope RT (%)	N/A
		N/A	Flare Traversable LT?	N/A	N/A Flare Traversable RT?	N/A
		N/A	Landing Length (in)	N/A	N/A DWS Provided?	N/A
	Surveyor Notes:	N/A	Landing Width (in)	N/A	N/A DWS Contrast?	N/A
	N/A	N/A	Landing Slope (%)	N/A	N/A DWS Length (in)	N/A
THE MEANER RIDGE RD	-	N/A	Landing X Slope (%)	N/A	N/A DWS Full Width?	N/A
		N/A	Landing Curb? (Y/N)	N/A	N/A DWS Offset (in)	N/A
6.6.6.		N/A	Shared Landing?	N/A		
	PROW/ADA:	N/A	Gutter Ponding?	N/A	N/A Gutter Slope (%)	N/A
	Not Found, R304.5.1, R304.5.3	N/A	Gutter Lip Ht (in)	N/A	N/A Gutter X Slope (%)	N/A
		N/A	Painted X Walk1?	No	N/A Painted X Walk2?	N/A
			X Walk 1 Direction	To S	X Walk 2 Direction	N/A
		N/A	X Walk 1 Width (in)	N/A	N/A X Walk 2 Width (in)	N/A
Street 1 Name KEENER RIDGE RD	_		X Walk 1 Slope (%)	3.9	X Walk 2 Slope (%)	N/A
Stop Condition-Street 2 StopSign			X Walk 1 X Slope (%)	4.1	X Walk 2 X Slope (%)	N/A
Street 2 Name N/A		N/A	Ramp inside XWalk1?	N/A	N/A Ramp inside XWalk2?	N/A
Stop Condition-Street 1 N/A			Road Slope (%)	N/A	N/A Clear Space?	N/A
			Road X Slope (%)	N/A	N/A Clear Space to XWalk (in)	N/A
		N/A	Any Obstructions?	N/A	N/A Storm Grate/Utility Hazard?	N/A
	Total Cost: \$ 1	850.00	Obstruction Type		Storm Grate/Utility Type	
				N/A		N/A

Yes Surface Condition? (G/P)

Good

