

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 48774Main Street:TURNING_WHEEL_DRCross Street: OLD_FORESTER_LNLocation:NWADA ID: 6CA60526CFC2Ramp Type:PerpDiagInitial Pass/Fail: FailOverall Compliance: NoSeverity Score:8.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name Stop Condition-Street 2 Street 2 Name Stop Condition-Street 1 OLD FORESTER LN StopSign TURNING WHEEL DR None

Fossible Solution					
Possible Solutions:					
Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.					
Surveyor Notes:					
N/A					
PROW/ADA:					
R304.5.1	1				

Total Cost: \$ 3200.00

Field Measurements/Component Compliance							
Comp	liance Description	Data	Comp	liance Description	Data		
N/A	Ramp Length (in)	74.0	Yes	Ramp Slope (%)	5.7		
No	Ramp Width (in)	45.5	Yes	Ramp XSlope (%)	1.2		
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A		
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A		
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A		
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A		
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A		
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A		
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A		
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A		
N/A	Shared Landing?	N/A					
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A		
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A		
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No		
	X Walk 1 Direction	To S		X Walk 2 Direction	To E		
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A		
	X Walk 1 Slope (%)	4.8		X Walk 2 Slope (%)	4.5		
	X Walk 1 X Slope (%)	3.2		X Walk 2 X Slope (%)	3.3		
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A		
	Road Slope (%)	0.7	N/A	Clear Space?	N/A		
	Road X Slope (%)	5.0	N/A	Clear Space to XWalk (in)	N/A		
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A		
	Obstruction Type			Storm Grate/Utility Type			
		N/A			N/A		
			Yes	Surface Condition? (G/P)	Good		





