cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 11956	N_COLLEGE_ST			Location:	S				
		Main Street: E_9TH_ST							
ADA ID: 6D1926903551 Ramp Type: BlendTrans1 II			Initial	itial Pass/Fail: Pass Overall Compliance: No				o Severity Score:	17.5
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
		Possible Solutions:		Compliance Description Data Complia			liance Description	Data	
		Remove & Replace Curb Ra	mp With	N/A	Ramp Length (in)	30.0	Yes	BlendTrans Slope (%)	2.9
		Two New Directional Ramps		Yes	Ramp Width (in)	48.0	Yes	BlendTrans XSlope (%)	1.4
		Equivalent. Restripe Crosswalk(To Provide Clear space. Grind Gutter Lip.		N/A	Flare Type LT	Sloped	N/A	Flare Type RT	Sloped
			na	N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	2.9
				N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
				No	Landing Length (in)	24.0	Yes	DWS Provided?	Yes
		Surveyor Notes:		Yes	Landing Width (in)	48.0	Yes	DWS Contrast?	Yes
		N/A		Yes	Landing Slope (%)	1.1	Yes	DWS Length (in)	24.0
				Yes	Landing X Slope (%)	0.6	No	DWS Full Width?	No
				N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	6.0
				N/A	Shared Landing?	No			
		PROW/ADA:		No	Gutter Ponding?	Yes	Yes	Gutter Slope (%)	4.7
		R304.2.1, Not Found, R305.1.4,	.4,	No	Gutter Lip Ht (in)	1.5	Yes	Gutter X Slope (%)	0.2
	10.1	R305.2, R302.7, R302.7.2		N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	Yes
		8			X Walk 1 Direction	To NE		X Walk 2 Direction	To NW
					X Walk 1 Width (in)	95.0		X Walk 2 Width (in)	95.0
Street 1 Name	E 9TH ST				X Walk 1 Slope (%)	3.9		X Walk 2 Slope (%)	4.3
Stop Condition-Street 1	Signal				X Walk 1 X Slope (%)	0.7		X Walk 2 X Slope (%)	3.0
Street 2 Name	N COLLEGE ST			Yes	Ramp inside XWalk1?	Yes	Yes	Ramp inside XWalk2?	Yes
Stop Condition-Street 2	Signal				Road Slope (%)	0.6		Clear Space?	Yes
					Road X Slope (%)	3.3	No	Clear Space to XWalk (in)	N/A
				Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
		Total Cost: \$	3900.00		Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A
							I		







Yes

Yes

Surface Condition? (G/P)

Curb Slope (%)

Good

2.1