

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: N/A	Main Street: MAYFLOWER_RD			treet:	HENDREN_AV	Location:	NW			
ADA ID: 6DBDAA44FA0C	Ramp Type: Directional1			Initial Pass/Fail: Fail Overall Compliance: No					1.25	
									1.20	
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance   Compliance Data   Compliance Data						
		Possible Solutions:		Compliance Description			Data Compliance Description			
		Remove & Replace Entire Ramp		N/A	Ramp Length (in)	108.0	N/A	Grade Break?	N/A	
	Carlo Barran			Yes	Ramp Width (in)	56.0	N/A	Grade Break Slope (%)	0.0	
				Yes	Ramp Slope (%)	7.9	N/A	Grade Break XSlope (%)	0.0	
				No	Ramp XSlope (%)	2.5				
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
E Contraction of the second seco	- AND V			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	0.0	
HENDRENLAY		Surveyor Notes:		N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
		N/A		N/A	Landing Length (in)	0.0	N/A	DWS Provided?	N/A	
				N/A	Landing Width (in)	0.0	N/A	DWS Contrast?	N/A	
La E	1 . 5/ 50			N/A	Landing Slope (%)	0.0	N/A	DWS Length (in)	N/A	
A A A A A A A A A A A A A A A A A A A				N/A	Landing X Slope (%)	0.0	N/A	DWS Full Width?	N/A	
and the grant of the		PROW/ADA:		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset LT (in)	N/A	
		R304.5.3		N/A	Shared Landing?	N/A	N/A	DWS Offset RT (in)	N/A	
				N/A	Gutter Ponding?	0.0	N/A	Gutter Slope (%)	N/A	
ALLEN BOR				N/A	Gutter Lip Ht (in)	0.0	N/A	Gutter X Slope (%)	N/A	
				N/A	Painted X Walk1?	No		Road Slope (%)	3.0	
Street 1 Name	HENDREN AV				X Walk 1 Direction	To S		Road X Slope (%)	1.6	
Stop Condition-Street 1	StopSign				X Walk 1 Width (in)	N/A		Clear Space?	N/A	
Street 2 Name	N/A				X Walk 1 Slope (%)	3.0	N/A	Clear Space to XWalk (in)	N/A	
Stop Condition-Street 2	N/A				X Walk 1 X Slope (%)	1.6	N/A	Storm Grate/Utility Hazard?	N/A	
				N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type		
				N/A	Any Obstructions?	N/A			N/A	
		Total Cost: \$	1600.00		Obstruction Type		Yes	Surface Condition? (G/P)	Good	
						N/A	N/A	Curb Slope (%)	1.0	

