


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 50272	Main Street: SOUTH_BV	Cross Street: WHITTON_ST	Location: SE
ADA ID: 6E34F8836E4D	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 12.5	

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance			
	Possible Solutions:				
	Remove & Replace Entire Ramp.				
	Surveyor Notes:				
	N/A				
	PROW/ADA:				
	Not Found, R304.5.3				
		Compliance	Description	Data	Compliance
		N/A	Ramp Length (in)	90.0	Yes
		Yes	Ramp Width (in)	48.0	No
		N/A	Flare Type LT	N/A	N/A
		N/A	Flare Slope LT (%)	N/A	N/A
		N/A	Flare Traversable LT?	N/A	N/A
		N/A	Landing Length (in)	N/A	N/A
		N/A	Landing Width (in)	N/A	N/A
		N/A	Landing Slope (%)	N/A	N/A
		N/A	Landing X Slope (%)	N/A	N/A
		N/A	Landing Curb? (Y/N)	N/A	N/A
		N/A	Shared Landing?	N/A	
		N/A	Gutter Ponding?	N/A	N/A
		N/A	Gutter Lip Ht (in)	N/A	N/A
		N/A	Painted X Walk1?	Yes	N/A
			X Walk 1 Direction	To NW	
		N/A	X Walk 1 Width (in)	118.0	N/A
			X Walk 1 Slope (%)	1.4	
			X Walk 1 X Slope (%)	0.7	
		N/A	Ramp inside XWalk1?	Yes	N/A
			Road Slope (%)	N/A	N/A
			Road X Slope (%)	N/A	N/A
		N/A	Any Obstructions?	N/A	N/A
			Obstruction Type		
				N/A	N/A
				Yes	Surface Condition? (G/P)
					Good
Street 1 Name	SOUTH BV				
Stop Condition-Street 2	Signal				
Street 2 Name	N/A				
Stop Condition-Street 1	N/A				
Total Cost:	\$	1850.00			

