cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 43371	Main Street: BERNARDY_LN			Street:	SIMONTON_DR	Location:	NW		
ADA ID: 6EF9759B8F8F	Ramp Type: PerpDiag			Initial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	1.25
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
		Possible Solutions:						ompliance Description Data	
EMONIONER		Remove & Replace Curb Ramp V	Nith	N/A	Ramp Length (in)	49.0	Yes	Ramp Slope (%)	6.7
		Two New Directional Ramps or	VILII	Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	2.8
		Equivalent.		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
		Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		· ·		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
		N/A			- · · · /		N/A	DWS Full Width?	
				N/A	Landing X Slope (%)	N/A			N/A
e de la companya de l				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
				N/A	Shared Landing?	N/A			
		PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
		Not Found, R304.5.3		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
	and the			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
Service and the service of the servi	110000	1			X Walk 1 Direction	To S		X Walk 2 Direction	To E
				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name	SIMONTON DR				X Walk 1 Slope (%)	0.8		X Walk 2 Slope (%)	4.3
Stop Condition-Street 2	None				X Walk 1 X Slope (%)	3.8		X Walk 2 X Slope (%)	1.2
Street 2 Name	BERNARDY LN			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	StopSign				Road Slope (%)	3.9	N/A	Clear Space?	N/A
					Road X Slope (%)	4.8	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Total Cost: \$ 3	200.00		Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A

Yes Surface Condition? (G/P)

Good

