


Intersection ID: 10027410	Main Street: GOLF_ACRES_DR	Cross Street: N/A	Location:	S
ADA ID: 6F3A0B4EE07F	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 12.5

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance												
	Possible Solutions:					Compliance			Description			Data			
	Remove & Replace Entire Ramp.					N/A			Ramp Length (in)			47.0			
						Yes			Ramp Width (in)			48.0			
						N/A			Flare Type LT			N/A			
						N/A			Flare Slope LT (%)			N/A			
						N/A			Flare Traversable LT?			N/A			
						N/A			Landing Length (in)			N/A			
						N/A			Landing Width (in)			N/A			
						N/A			Landing Slope (%)			N/A			
						N/A			Landing X Slope (%)			N/A			
Surveyor Notes:					N/A			N/A			Landing Curb? (Y/N)			N/A	
PROW/ADA:					R304.5.3			N/A			Shared Landing?			N/A	
					N/A			N/A			Gutter Ponding?			N/A	
					N/A			N/A			Gutter Lip Ht (in)			N/A	
					N/A			No			Painted X Walk1?			N/A	
								To NW			X Walk 1 Direction			N/A	
					N/A			N/A			X Walk 1 Width (in)			N/A	
											X Walk 1 Slope (%)			1.9	
											X Walk 1 X Slope (%)			4.8	
					N/A			N/A			Ramp inside XWalk1?			N/A	
								N/A			Road Slope (%)			N/A	
								N/A			Road X Slope (%)			N/A	
					N/A			N/A			Any Obstructions?			N/A	
											Obstruction Type				
								N/A						N/A	
								Yes			Surface Condition? (G/P)			Good	

