


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 53804	Main Street: NATHAN_DR	Cross Street: PITZER_DR	Location: S
ADA ID: 768BE11F46A5	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 26.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		No	Ramp Length (in)	95.5
			Yes	Ramp Width (in)	59.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>Not Found, R304.2.2, R304.5.3</p>			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Gutter Ponding?	Yes
			N/A	Gutter Lip Ht (in)	N/A
			No	Painted X Walk1?	N/A
			To NW	X Walk 1 Direction	N/A
			N/A	X Walk 1 Width (in)	N/A
			4.4	X Walk 1 Slope (%)	N/A
			3.5	X Walk 1 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	N/A
			N/A	Road Slope (%)	N/A
			N/A	Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	N/A
Total Cost:			\$ 1850.00		
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

