


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 10032740	Main Street: N SHARON AMITY RD	Cross Street: N/A	Location: SE
ADA ID: 791412908182	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	
Severity Score: 12.5			

	Possible Solutions:								
	Remove & Replace Entire Ramp.								
	Surveyor Notes:								
	N/A								
	PROW/ADA:								
	R304.2.2								
	Street 1 Name	ENTRANCE							
	Stop Condition-Street 2	StopSign							
	Street 2 Name	N/A							
	Stop Condition-Street 1	N/A							
Total Cost:		\$	1850.00						
				Compliance	Description	Data	Compliance	Description	Data
				N/A	Ramp Length (in)	26.0	No	Ramp Slope (%)	8.7
				Yes	Ramp Width (in)	60.0	Yes	Ramp XSlope (%)	0.1
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
				N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
				N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
				N/A	Shared Landing?	N/A			
				N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
				N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
				N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
					X Walk 1 Direction	To SW		X Walk 2 Direction	N/A
				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
					X Walk 1 Slope (%)	3.2		X Walk 2 Slope (%)	N/A
					X Walk 1 X Slope (%)	1.3		X Walk 2 X Slope (%)	N/A
				N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
					Road Slope (%)	N/A	N/A	Clear Space?	N/A
					Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
					Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A
							Yes	Surface Condition? (G/P)	Good

