


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 52609		Main Street: SENATOR ROYALL DR	Cross Street: ALEXANDER VILLAGE MAIN DR	Location:	NE
ADA ID: 796D7A643CCD		Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 1.25
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
		Possible Solutions:	Compliance	Description	Data
		Remove & Replace Entire Ramp.	N/A	Ramp Length (in)	105.0
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>R304.5.3</p>			Yes	Ramp Width (in)	63.1
			Yes	Ramp Slope (%)	5.6
			No	Ramp XSlope (%)	3.9
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	0.0
			N/A	Landing Width (in)	0.0
			N/A	Landing Slope (%)	0.0
			N/A	Landing X Slope (%)	0.0
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	0.0
			N/A	Gutter Lip Ht (in)	0.0
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To S
				X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	0.9
				X Walk 1 X Slope (%)	4.3
			N/A	Ramp inside XWalk1?	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	N/A
Total Cost:		\$	1600.00		

