


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 7014	Main Street: BROOKWOOD_RD	Cross Street: BLAZE_MANOR_LN	Location: NE
ADA ID: 79D1DE2CE54E	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 21.25

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance																	
	Possible Solutions:		Compliance			Description			Data	Compliance			Description			Data			
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)						66.0	Yes	Ramp Slope (%)						5.8	
			No	Ramp Width (in)						44.5	No	Ramp XSlope (%)						6.0	
			N/A	Flare Type LT						N/A	N/A	Flare Type RT						N/A	
			N/A	Flare Slope LT (%)						N/A	N/A	Flare Slope RT (%)						N/A	
			N/A	Flare Traversable LT?						N/A	N/A	Flare Traversable RT?						N/A	
			N/A	Landing Length (in)						N/A	N/A	DWS Provided?						N/A	
			N/A	Landing Width (in)						N/A	N/A	DWS Contrast?						N/A	
			N/A	Landing Slope (%)						N/A	N/A	DWS Length (in)						N/A	
			N/A	Landing X Slope (%)						N/A	N/A	DWS Full Width?						N/A	
Surveyor Notes:		N/A			N/A			N/A			N/A			N/A			N/A		
PROW/ADA:		Not Found, R304.5.1, R304.5.3			N/A			N/A			N/A			N/A			N/A		
					X Walk 1 Direction			To W			X Walk 2 Direction			To S					
		N/A			X Walk 1 Width (in)			N/A			N/A			X Walk 2 Width (in)			N/A		
					X Walk 1 Slope (%)			1.8						X Walk 2 Slope (%)			3.7		
					X Walk 1 X Slope (%)			4.2						X Walk 2 X Slope (%)			2.8		
		N/A			Ramp inside XWalk1?			N/A			N/A			Ramp inside XWalk2?			N/A		
					Road Slope (%)			5.4			N/A			Clear Space?			N/A		
					Road X Slope (%)			1.5			N/A			Clear Space to XWalk (in)			N/A		
		N/A			Any Obstructions?			N/A			N/A			Storm Grate/Utility Hazard?			N/A		
					Obstruction Type									Storm Grate/Utility Type					
								N/A									N/A		
											Yes			Surface Condition? (G/P)			Good		
Total Cost:					\$			3200.00											
Street 1 Name		BLAZE MANOR LN																	
Stop Condition-Street 2		StopSign																	
Street 2 Name		BROOKWOOD RD																	
Stop Condition-Street 1		None																	

Street 1 Name	BLAZE MANOR LN
Stop Condition-Street 2	StopSign
Street 2 Name	BROOKWOOD RD
Stop Condition-Street 1	None

