


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10040845		Main Street: WAKEFIELD_DR		Cross Street: N/A		Location:		N			
ADA ID: 79DDF738E693		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: No		Severity Score: 0.25			
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance							
				Possible Solutions:		Compliance		Description		Data	
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		124.0	
Surveyor Notes:				N/A		Yes		Ramp Width (in)		48.0	
						Yes		Ramp Slope (%)		7.4	
PROW/ADA:				R304.2.2-Perp, R304.3.2-Para, R305.2		Yes		Ramp XSlope (%)		3.8	
						N/A		Flare Type LT		N/A	
						Yes		Flare Slope LT (%)		2.9	
						N/A		Flare Traversable LT?		Yes	
						Yes		Landing Length (in)		57.0	
						Yes		Landing Width (in)		53.0	
						No		Landing Slope (%)		4.1	
						Yes		Landing X Slope (%)		1.3	
						N/A		Landing Curb? (Y/N)		N/A	
						N/A		Shared Landing?		No	
						Yes		Gutter Ponding?		No	
						Yes		Gutter Lip Ht (in)		0.0	
						N/A		Painted X Walk1?		No	
								X Walk 1 Direction		To S	
								X Walk 1 Width (in)		N/A	
								X Walk 1 Slope (%)		8.5	
								X Walk 1 X Slope (%)		6.8	
						N/A		Ramp inside XWalk1?		N/A	
						Yes		Any Obstructions?		No	
								Obstruction Type		Yes	
								Surface Condition? (G/P)		Good	
								Curb Slope (%)		N/A	
										0.7	
Street 1 Name				ENTRANCE							
Stop Condition-Street 1				None							
Street 2 Name				N/A							
Stop Condition-Street 2				N/A							
Total Cost:				\$		1600.00					

