

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

51.5

55.0

6.4

6.7

9.0

4.4

N/A

Intersection ID: 12013 Main Street: FREEDOM DR Cross Street: W MOREHEAD ST Location: NW **Overall Compliance: No** ADA ID: 7B431EF2D481 Ramp Type: Combination1 Initial Pass/Fail: Fail Severity Score: 33.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

N/A

Yes

Yes

Nο

Yes

N/A

Compliance Description

Ramp Length RT (in)

Ramp Width RT (in)

Ramp Slope RT (%)

Ramp Slope (%)

Flare Type RT

Ramp XSlope (%)

Flare Slope RT (%)

DWS Provided?

DWS Contrast?

DWS Length (in)

DWS Full Width?

DWS Offset (in)

Gutter Slope (%)

Gutter X Slope (%)

Painted X Walk2?

X Walk 2 Direction

Flare Traversable RT?

Ramp XSlope RT (%)

Data

45.0

49.0

3.4

6.2 No

76.0

47.0

N/A

Yes

To SW

Ramp Length LT (in)

Ramp Width LT (in)

Ramp Slope LT (%)

Ramp Length (in)

Ramp Width (in)

Flare Slope LT (%)

Landing Length (in)

Landing Width (in)

Landing Slope (%)

Landing X Slope (%)

Landing Curb? (Y/N)

Shared Landing?

Gutter Ponding?

Gutter Lip Ht (in)


Painted X Walk1?

X Walk 1 Direction

Flare Traversable LT?

Flare Type LT

Ramp XSlope LT (%)



Street 1 Name Signal Stop Condition-Street 1 W MOREHEAD ST N/A Street 2 Name Stop Condition-Street 2 N/A Possible Solutions: Compliance Description N/A Remove & Replace Entire Ramp. Yes Yes No N/A No Surveyor Notes: N/A LT RP < 5% N/A N/A N/A N/A PROW/ADA: N/A Not Found, R304.5.1, R304.2.2, N/A R304.5.3 N/A N/A N/A N/A N/A



Total Cost:



