


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 3443	Main Street: REAMES_RD	Cross Street: PERIMETER_PY	Location:	E
ADA ID: 7C1205D85049	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 22.5

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance							
	Possible Solutions:		Compliance			Description			Data	
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	71.0	No	Ramp Slope (%)	9.1		
			No	Ramp Width (in)	47.5	Yes	Ramp XSlope (%)	2.4		
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A		
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A		
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A		
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A		
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A		
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A		
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A		
		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A			
		N/A	Shared Landing?	N/A						
		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A			
		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A			
		N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A			
			X Walk 1 Direction	To SW		X Walk 2 Direction	N/A			
		N/A	X Walk 1 Width (in)	100.0	N/A	X Walk 2 Width (in)	N/A			
			X Walk 1 Slope (%)	1.2		X Walk 2 Slope (%)	N/A			
			X Walk 1 X Slope (%)	4.5		X Walk 2 X Slope (%)	N/A			
		N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A			
			Road Slope (%)	N/A	N/A	Clear Space?	N/A			
			Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A			
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A			
			Obstruction Type			Storm Grate/Utility Type				
					N/A		N/A			
					Yes	Surface Condition? (G/P)	Good			

