

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Yes

Surface Condition? (G/P)

Good

Intersection ID: 17321	Main Street: QUEENS_RD_EAST			Cross	Street:	QUEENS_RD_WEST	Location:	NE		
ADA ID: 7CA37B7524AE	B7524AE Ramp Type: PerpDiag			Initial	Pass/Fa	ail: Fail Overall (	o Severity Score:	21.25		
Codes/Mitigation Info/Possible Solution					Field Measurements/Component Compliance					
		Possible Solutions:			Comp	liance Description	Data Compliance Description			Data
		Remove & Replace Curb	Ramr	With	N/A	Ramp Length (in)	57.0	No	Ramp Slope (%)	8.8
		Two New Directional Ram	-		No	Ramp Width (in)	47.0	Yes	Ramp XSlope (%)	1.4
		Equivalent.	•		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
					N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
					N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
	The same the for	Surveyor Notes:			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
					N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		N/A			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
B. B.					N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
2	MS RD LEAD				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
	UEEUCE				N/A	Shared Landing?	N/A			
QUEENS_RD_WEST		PROW/ADA:			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
(HOL		Not Found, R304.5.1, R30	14 2 2		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
E STATISTICS				1	N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
					X Walk 1 Direction	To W		X Walk 2 Direction	To S	
	The second second				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name	ROSWELL AV	-				X Walk 1 Slope (%)	6.0		X Walk 2 Slope (%)	1.7
Stop Condition-Street 2	StopSign					X Walk 1 X Slope (%)	0.6		X Walk 2 X Slope (%)	3.8
Street 2 Name	QUEENS RD EAST				N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	StopSign					Road Slope (%)	1.5	N/A	Clear Space?	N/A
						Road X Slope (%)	2.7	N/A	Clear Space to XWalk (in)	N/A
					N/A	Any Obstructions?	2./ N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Total Cost:	\$	3200.00		Obstruction Type			Storm Grate/Utility Type	
			Ŧ	3200.00			N/A	1	closini crato, cuinty rypo	N/A
							17/4			11/2

