


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 15495	Main Street: CHEROKEE_RD	Cross Street: EASTOVER_RD	Location: SE
ADA ID: 7CABF657A387	Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	
Severity Score: 33.75			

	Possible Solutions:				
	Remove & Replace Entire Ramp.				
	Surveyor Notes:				
	N/A				
	PROW/ADA:				
	R304.5.1, R304.5.3				
	Street 1 Name	CHEROKEE RD			
	Stop Condition-Street 1	None			
	Street 2 Name	N/A			
	Stop Condition-Street 2	N/A			
Total Cost:		\$ 1600.00			
			Compliance	Description	Data
			N/A	Ramp Length (in)	69.0
			No	Ramp Width (in)	39.0
			Yes	Ramp Slope (%)	1.6
			No	Ramp XSlope (%)	12.4
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	0.0
			N/A	Landing Width (in)	0.0
			N/A	Landing Slope (%)	0.0
			N/A	Landing X Slope (%)	0.0
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	0.0
			N/A	Gutter Lip Ht (in)	0.0
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To NW
				X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	5.2
				X Walk 1 X Slope (%)	2.1
			N/A	Ramp inside XWalk1?	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	10.0

