

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 47396	Main Street: FLAT_RIVER_DR	Cross Street: KENBROOKE_DR	Location: S
ADA ID: 7FAD5E361F2B	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 26.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	22.5	No	Ramp Slope (%)	13.9
			Yes	Ramp Width (in)	50.0	No	Ramp XSlope (%)	2.2
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
Surveyor Notes:	N/A		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A			
			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
			N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To E		X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	51.0	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	5.5		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	3.8		X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
PROW/ADA: R304.2.2, R304.5.3				Road Slope (%)	N/A	N/A	Clear Space?	N/A
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
			N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
				Obstruction Type			Storm Grate/Utility Type	
					N/A			N/A
						Yes	Surface Condition? (G/P)	Good
	Total Cost:		\$	1850.00				

Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

N/A

PROW/ADA:

R304.2.2, R304.5.3

Total Cost: \$ 1850.00

Street 1 Name	KENBROOKE DR
Stop Condition-Street 2	YieldSign
Street 2 Name	N/A
Stop Condition-Street 1	N/A

