


# Access Compliance Report Public Rights-of-Way (Curb Ramps)

Intersection ID: 5468      Main Street: N\_TRYON\_ST      Cross Street: J\_W\_CLAY\_BV      Location: S

ADA ID: 80FA5E2F2670      Ramp Type: Perp      Initial Pass/Fail: Fail      Overall Compliance: No      Severity Score: 22.5

**Codes/Mitigation Info/Possible Solution**      **Field Measurements/Component Compliance**



Possible Solutions:  
**Remove & Replace Entire Ramp.**

Surveyor Notes:  
**N/A**

PROW/ADA:  
**R304.5.1, R304.2.2, R304.5.3**

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	97.0	No	Ramp Slope (%)	10.2
No	Ramp Width (in)	47.5	No	Ramp XSlope (%)	2.7
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To NW		X Walk 2 Direction	N/A
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	2.9		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	1.1		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A	N/A	Clear Space?	N/A
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good

Street 1 Name      **N TRYON ST**  
 Stop Condition-Street 2      **Signal**  
 Street 2 Name      **N/A**  
 Stop Condition-Street 1      **N/A**

Total Cost:      \$      **1850.00**

