


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 20986	Main Street: W_ARROWOOD_RD	Cross Street: GREEN_RIDGE_DR	Location: N
ADA ID: 83CE20980AE1	Ramp Type: MedianPerp	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	62.5	No	Ramp Slope (%)	10.0
			Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	3.0
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>R304.2.2, R304.5.3</p>			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A			
			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
			N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To SE		X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	102.0	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	0.2		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	2.5		X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
			Road Slope (%)	N/A	N/A	Clear Space?	N/A	
			Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
			Obstruction Type			Storm Grate/Utility Type		
				N/A			N/A	
					Yes	Surface Condition? (G/P)	Good	
Total Cost:		\$ 1650.00						
Street 1 Name		GREEN RIDGE DR						
Stop Condition-Street 2		None						
Street 2 Name		N/A						
Stop Condition-Street 1		N/A						

