


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 9944	Main Street: CHESHIRE_AV	Cross Street: TUCKASEEGEE_RD	Location: W
ADA ID: 83F2989B72E3	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 30	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		Yes	Ramp Slope (%)	7.2
			No	Ramp Width (in)	6.2
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p>			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	0.5
			N/A	Painted X Walk1?	No
			To SE	X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	N/A
			N/A	X Walk 1 Slope (%)	4.9
			N/A	X Walk 1 X Slope (%)	3.5
			N/A	Ramp inside XWalk1?	N/A
<p>PROW/ADA:</p> <p>Not Found, R304.5.1, R304.5.3</p>			N/A	Road Slope (%)	N/A
			N/A	Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	
			N/A		
			N/A		
			N/A		
			N/A		
			N/A		
			N/A		
<p>Street 1 Name</p> <p>CHESHIRE AV</p> <p>Stop Condition-Street 2</p> <p>StopSign</p> <p>Street 2 Name</p> <p>N/A</p> <p>Stop Condition-Street 1</p> <p>N/A</p>			N/A	Clear Space?	N/A
			N/A	Clear Space to XWalk (in)	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
				Storm Grate/Utility Type	
			N/A		
			N/A		
			N/A		
			N/A		
			N/A		
			N/A		
<p>Total Cost:</p> <p>\$ 1850.00</p>			Yes	Surface Condition? (G/P)	Good

