

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 15007 Main Street: BARR_DR Cross Street: JENKINS_DR Location: NW **Overall Compliance: No** ADA ID: 8425F4B117B0 Ramp Type: Perp Initial Pass/Fail: Fail **Severity Score:** 25

Codes/Mitigation Info/Possible Solution



	The second secon
Street 1 Name	BARR DR
Stop Condition-Street 2	StopSign
Street 2 Name	N/A
Ston Condition-Street 1	N/A

Possible Solutions:	Cor
Remove & Replace Entire Ramp.	N/A
	Yes
	N/A
	N/A
	N/A
	N/A
Surveyor Notes:	N/A
N/A	N/A
	N/A
	N/A
	N/A
PROW/ADA:	N/A
Not Found, R304.5.3	N/A
,	N/A
	N/A
	N/A

Total Cost:		\$ 1850.00
	Filly American	

Field Measurements/Component Compliance									
Comp	liance Description	Data	Comp	liance	Description	Data			
N/A	Ramp Length (in)	92.0	Yes	Ram	Slope (%)	7.1			
Yes	Ramp Width (in)	48.0	No	Ram	XSlope (%)	7.1			
N/A	Flare Type LT	N/A	N/A Flare Type RT		N/A				
N/A	Flare Slope LT (%)	N/A	N/A Flare Slope RT (%)		N/A				
N/A	Flare Traversable LT?	N/A	N/A	Flare	Traversable RT?	N/A			
N/A	Landing Length (in)	N/A	N/A	DWS	Provided?	N/A			
N/A	Landing Width (in)	N/A	N/A	DWS	Contrast?	N/A			
N/A	Landing Slope (%)	N/A	N/A	DWS	Length (in)	N/A			
N/A	Landing X Slope (%)	N/A	N/A	DWS	Full Width?	N/A			
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS	Offset (in)	N/A			
N/A	Shared Landing?	N/A							
N/A	Gutter Ponding?	N/A	N/A	Gutte	er Slope (%)	N/A			
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutte	er X Slope (%)	N/A			
N/A	Painted X Walk1?	No	N/A	Paint	ed X Walk2?	N/A			
	X Walk 1 Direction	To SW		X Wa	lk 2 Direction	N/A			
N/A	X Walk 1 Width (in)	N/A	N/A	X Wa	lk 2 Width (in)	N/A			
	X Walk 1 Slope (%)	0.9		X Wa	lk 2 Slope (%)	N/A			
	X Walk 1 X Slope (%)	1.4		X Wa	lk 2 X Slope (%)	N/A			
N/A	Ramp inside XWalk1?	N/A	N/A	Ram	o inside XWalk2?	N/A			
	Road Slope (%)	N/A	N/A	Clear	Space?	N/A			
	Road X Slope (%)	N/A	N/A	Clear	Space to XWalk (in)	N/A			
N/A	Any Obstructions?	N/A	N/A	Storn	n Grate/Utility Hazard?	N/A			
	Obstruction Type			Storn	n Grate/Utility Type				
		N/A				N/A			
			Yes	Surfa	ce Condition? (G/P)	Good			





