


Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 53971	Main Street: BEREWICK_TOWN_CENTRE	Cross Street: CADEN_RD	Location: NW
ADA ID: 84CF74E1584A	Ramp Type: BlendTrans1	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 0	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
 Street 1 NameBEREWICK TOWN CENTRE Stop Condition-Street 1None Street 2 NameN/A Stop Condition-Street 2N/A	Possible Solutions:		ComplianceDescriptionData			ComplianceDescriptionData		
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)	181.0	Yes	BlendTrans Slope (%)	2.9
			Yes	Ramp Width (in)	96.0	Yes	BlendTrans XSlope (%)	0.1
			Yes	Flare Type L	Curbed_NoWalkSurface	Yes	Flare Type R	Curbed_NoWalkSurface
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
			Yes	Landing Length (in)	95.0	Yes	DWS Provided?	Yes
			Yes	Landing Width (in)	96.0	Yes	DWS Contrast?	Yes
			Yes	Landing Slope (%)	1.5	Yes	DWS Length (in)	24.0
			Yes	Landing X Slope (%)	1.1	Yes	DWS Full Width?	Yes
Surveyor Notes:		N/A	N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	7.0
PROW/ADA:		Not Found, R305.2	N/A	Shared Landing?	No			
			Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	1.1
			Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	1.1
			N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To SW		X Walk 2 Direction	N/A
				X Walk 1 Width (in)	97.5		X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	2.5		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	1.1		X Walk 2 X Slope (%)	N/A
			Yes	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	1.1		Clear Space?	Yes
				Road X Slope (%)	2.5	N/A	Clear Space to XWalk (in)	N/A
			Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
				Obstruction Type			Storm Grate/Utility Type	
						N/A		N/A
						Yes	Surface Condition? (G/P)	Good
						No	Curb Slope (%)	12.1
Total Cost:		\$3200.00						

