

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

55.0

60.0

9.4

1.6

5.7

5.2

N/A

Good 13.2

Intersection ID: 12655 Main Street: GOLF_ACRES_DR Cross Street: MORRIS_FIELD_DR Location: NW

ADA ID: 84F70460C9AF Ramp Type: Combination1 Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 33.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name
StopSign
Stop Condition-Street 1
GOLF ACRES DR
Street 2 Name
N/A
Stop Condition-Street 2
N/A

Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

LT RP < 5%

PROW/ADA:

Not Found, R304.5.1, R304.5.3, R304.3.2

Total Cost: \$



N/A

N/A

N/A

N/A

N/A

Yes

Clear Space?

Any Obstruction?

Obstruction Type

Curb Slope (%)

Clear Space to XWalk (in)

Storm Grate/Utility Hazard?

Storm Grate/Utility Type

Surface Condition? (G/P)







Road Slope (%)

1800.00