


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 17587	Main Street: KNICKERBOCKER_DR	Cross Street: MELBA_DR	Location: W
ADA ID: 881F69A5D39A	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 0	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		Compliance	Description	Data
			N/A	Ramp Length (in)	47.0
			Yes	Ramp Width (in)	48.0
			N/A	Flare Type LT	Sloped
			N/A	Flare Slope LT (%)	5.5
			N/A	Flare Traversable LT?	Yes
			Yes	Landing Length (in)	60.0
			Yes	Landing Width (in)	48.0
			Yes	Landing Slope (%)	1.1
<p>Surveyor Notes:</p> <p>N/A</p>			Yes	Landing X Slope (%)	0.3
			N/A	Landing Curb? (Y/N)	No
			N/A	Shared Landing?	No
			Yes	Gutter Ponding?	No
			Yes	Gutter Lip Ht (in)	0.0
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To S
			N/A	X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	4.7
				X Walk 1 X Slope (%)	1.3
<p>PROW/ADA:</p> <p>Not Found</p>			N/A	Ramp inside XWalk1?	N/A
				Road Slope (%)	N/A
				Road X Slope (%)	N/A
			Yes	Any Obstructions?	No
				Obstruction Type	
<p>Total Cost:</p> <p>\$ 1850.00</p>			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

