


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 5506	Main Street: COLIN_CREEK_LN	Cross Street: MOUNTAIN_FLOWER_CT	Location:	N
ADA ID: 8A741C43271E	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 1.25

Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
	Possible Solutions:			Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.			N/A	Ramp Length (in)	48.0	Yes	Ramp Slope (%)	5.8
				Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	3.5
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
				N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
				N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
Surveyor Notes:			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	N/A
PROW/ADA:			N/A	Shared Landing?	N/A				
Not Found, R304.5.3			N/A	Gutter Ponding?	N/A	N/A	N/A	Gutter Slope (%)	N/A
			N/A	Gutter Lip Ht (in)	N/A	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	No	N/A	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To S			X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	N/A	N/A	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	0.5			X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	0.5			X Walk 2 X Slope (%)	N/A
Street 1 Name			MOUNTAIN FLOWER CT	N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 2			StopSign		Road Slope (%)	N/A	N/A	Clear Space?	N/A
Street 2 Name			N/A		Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
Stop Condition-Street 1			N/A	N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
				Obstruction Type				Storm Grate/Utility Type	
Total Cost:			\$ 1850.00			N/A			N/A
						Yes	Surface Condition? (G/P)	Good	

Street 1 Name	MOUNTAIN FLOWER CT
Stop Condition-Street 2	StopSign
Street 2 Name	N/A
Stop Condition-Street 1	N/A

