cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 16083	Main Street: LLEWELLYN_PL		Cross S	Street:	LOCKLEY_DR	Location:	NW		
ADA ID: 8B567149F744	Ramp Ty	Ramp Type: PerpDiag		Initial Pass/Fail: Fail Overall Compliance: No				Severity Score:	10
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
		Possible Solutions:		Compliance Description			Data Compliance Description		
LOCALLEY DE		Remove & Replace Curb Ramp \	Nith	N/A	Ramp Length (in)	70.0	Yes	Ramp Slope (%)	8.1
		Two New Directional Ramps or Equivalent.		No	Ramp Width (in)	45.0	No	Ramp XSlope (%)	4.0
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
		Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
		<i>x</i>		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
				N/A	Shared Landing?	N/A			
and the second s		PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		Not Found, R304.5.1, R304.5.3		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
	P in '			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
a little wind the	a fina a				X Walk 1 Direction	To S		X Walk 2 Direction	To SE
a the said and the first the said				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name	LOCKLEY DR				X Walk 1 Slope (%)	0.8		X Walk 2 Slope (%)	2.5
Stop Condition-Street 2	None				X Walk 1 X Slope (%)	3.4		X Walk 2 X Slope (%)	2.8
Street 2 Name	LLEWELLYN PL			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	StopSign				Road Slope (%)	3.4	N/A	Clear Space?	N/A
					Road X Slope (%)	4.4	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Total Cost: \$	3200.00		Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A
							•		

Yes Surface Condition? (G/P)

Good

