

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Intersection ID: 32024 Main Street: CORNWALLIS CAMP DR **Cross Street: STONECROFT PARK DR** Location: SW **ADA ID: 8BBF5EF07416** Ramp Type: PerpDiag Initial Pass/Fail: Fail **Overall Compliance: No** Severity Score: 21.25

**Codes/Mitigation Info/Possible Solution** 



Street 1 Name Stop Condition-Street 2 Street 2 Name Stop Condition-Street 1 STONECROFT PARK DR StopSign **CORNWALLIS CAMP DR** None

Possible Solutions: **Remove & Replace Curb Ramp With Two New Directional Ramps or** Equivalent. Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.1, R304.5.3

Total Cost: 3200.00

Field Measurements/Component Compliance							
	Compliance Description		Data	Comp	liance	Description	Data
	N/A	Ramp Length (in)	88.0	Yes	Ramp	Slope (%)	7.8
	No	Ramp Width (in)	40.0	No	Ramp	XSlope (%)	5.3
	N/A	Flare Type LT	N/A	N/A	Flare	Type RT	N/A
	N/A	Flare Slope LT (%)	N/A	N/A	Flare	Slope RT (%)	N/A
	N/A	Flare Traversable LT?	N/A	N/A	Flare	Traversable RT?	N/A
	N/A	Landing Length (in)	N/A	N/A	DWS	Provided?	N/A
	N/A	Landing Width (in)	N/A	N/A	DWS	Contrast?	N/A
	N/A	Landing Slope (%)	N/A	N/A	DWS	Length (in)	N/A
	N/A	Landing X Slope (%)	N/A	N/A	DWS	Full Width?	N/A
	N/A	Landing Curb? (Y/N)	N/A	N/A	DWS	Offset (in)	N/A
	N/A	Shared Landing?	N/A				
	N/A	Gutter Ponding?	N/A	N/A	Gutte	er Slope (%)	N/A
	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutte	er X Slope (%)	N/A
	N/A	Painted X Walk1?	No	N/A	Paint	ed X Walk2?	No
		X Walk 1 Direction	To NE		X Wa	lk 2 Direction	To NW
	N/A	X Walk 1 Width (in)	N/A	N/A	X Wa	lk 2 Width (in)	N/A
		X Walk 1 Slope (%)	1.9		X Wa	lk 2 Slope (%)	2.8
		X Walk 1 X Slope (%)	2.9		X Wa	lk 2 X Slope (%)	4.1
	N/A	Ramp inside XWalk1?	N/A	N/A	Ram	inside XWalk2?	N/A
		Road Slope (%)	2.3	N/A	Clear	Space?	N/A
		Road X Slope (%)	1.3	N/A	Clear	Space to XWalk (in)	N/A
	N/A	Any Obstructions?	N/A	N/A	Storn	n Grate/Utility Hazard?	N/A
		Obstruction Type			Storn	n Grate/Utility Type	
			N/A				N/A
				Yes	Surfa	ce Condition? (G/P)	Good





