


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

| | | | |
|---|------------------------------|--------------------------|---|
| Intersection ID: 21992 | Main Street: WESTINGHOUSE_BV | Cross Street: S_TRYON_ST | Location: NW |
| ADA ID: 8BC2647E129B | Ramp Type: Perp | Initial Pass/Fail: Fail | Overall Compliance: No |
| Codes/Mitigation Info/Possible Solution | | | Severity Score: 22.5 |
| | | | Field Measurements/Component Compliance |



Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.1, R304.2.2, R304.5.3

Total Cost: \$ 1850.00

| Compliance | Description | Data | Compliance | Description | Data |
|------------|-----------------------|-------|------------|-----------------------------|------|
| N/A | Ramp Length (in) | 91.0 | No | Ramp Slope (%) | 9.4 |
| No | Ramp Width (in) | 41.0 | No | Ramp XSlope (%) | 2.9 |
| N/A | Flare Type LT | N/A | N/A | Flare Type RT | N/A |
| N/A | Flare Slope LT (%) | N/A | N/A | Flare Slope RT (%) | N/A |
| N/A | Flare Traversable LT? | N/A | N/A | Flare Traversable RT? | N/A |
| N/A | Landing Length (in) | N/A | N/A | DWS Provided? | N/A |
| N/A | Landing Width (in) | N/A | N/A | DWS Contrast? | N/A |
| N/A | Landing Slope (%) | N/A | N/A | DWS Length (in) | N/A |
| N/A | Landing X Slope (%) | N/A | N/A | DWS Full Width? | N/A |
| N/A | Landing Curb? (Y/N) | N/A | N/A | DWS Offset (in) | N/A |
| N/A | Shared Landing? | N/A | | | |
| N/A | Gutter Ponding? | N/A | N/A | Gutter Slope (%) | N/A |
| N/A | Gutter Lip Ht (in) | N/A | N/A | Gutter X Slope (%) | N/A |
| N/A | Painted X Walk1? | Yes | N/A | Painted X Walk2? | N/A |
| | X Walk 1 Direction | To E | | X Walk 2 Direction | N/A |
| N/A | X Walk 1 Width (in) | 107.0 | N/A | X Walk 2 Width (in) | N/A |
| | X Walk 1 Slope (%) | 1.4 | | X Walk 2 Slope (%) | N/A |
| | X Walk 1 X Slope (%) | 0.9 | | X Walk 2 X Slope (%) | N/A |
| N/A | Ramp inside XWalk1? | Yes | N/A | Ramp inside XWalk2? | N/A |
| | Road Slope (%) | N/A | N/A | Clear Space? | N/A |
| | Road X Slope (%) | N/A | N/A | Clear Space to XWalk (in) | N/A |
| N/A | Any Obstructions? | N/A | N/A | Storm Grate/Utility Hazard? | N/A |
| | Obstruction Type | | | Storm Grate/Utility Type | |
| | | N/A | | | N/A |
| | | Yes | | Surface Condition? (G/P) | Good |

