

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Intersection ID: 31553 Main Street: CALDWELL RD **Cross Street: CALDWELL RIDGE PY** Location: ADA ID: 9039886CB09C Ramp Type: PerpDiag Initial Pass/Fail: Fail **Overall Compliance: No** Severity Score: 21.25

**Codes/Mitigation Info/Possible Solution** 

None

## Field Measurements/Component Compliance



**CALDWELL RIDGE PY** Street 1 Name Stop Condition-Street 2 StopSign Street 2 Name **CALDWELL RD** Stop Condition-Street 1

Possible Solutions: **Remove & Replace Curb Ramp With** Two New Directional Ramps or Equivalent. Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.1, R304.2.2

3200.00

Total Cost:

Fleid Measurements/Component Compliance						
	Comp	liance Description	Data	Comp	oliance Description	Data
	N/A	Ramp Length (in)	50.5	No	Ramp Slope (%)	8.4
	No	Ramp Width (in)	46.0	Yes	Ramp XSlope (%)	0.9
	N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
	N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
	N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
	N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
	N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
	N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
	N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
	N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
	N/A	Shared Landing?	N/A			
	N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
	N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
		X Walk 1 Direction	To SW		X Walk 2 Direction	To SE
	N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
		X Walk 1 Slope (%)	2.7		X Walk 2 Slope (%)	5.5
		X Walk 1 X Slope (%)	3.4		X Walk 2 X Slope (%)	0.8
	N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
		Road Slope (%)	0.2	N/A	Clear Space?	N/A
		Road X Slope (%)	5.6	N/A	Clear Space to XWalk (in)	N/A
	N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Obstruction Type			Storm Grate/Utility Type	
			N/A			N/A
				Yes	Surface Condition? (G/P)	Good
			· ·	-		





