


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 51443	Main Street: SHARON_RD	Cross Street: ASHLEY_PARK_LN	Location: NE
ADA ID: 90702BD50AAC	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 21.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	86.0
			No	Ramp Width (in)	45.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
Surveyor Notes: N/A			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			N/A	Painted X Walk1?	Yes
				X Walk 1 Direction	To NW
			N/A	X Walk 1 Width (in)	111.0
				X Walk 1 Slope (%)	3.6
				X Walk 1 X Slope (%)	0.2
			N/A	Ramp inside XWalk1?	Yes
PROW/ADA: R304.5.1, R304.2.2			N/A	Road Slope (%)	N/A
				Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	
Street 1 Name Stop Condition-Street 2 Street 2 Name Stop Condition-Street 1	SHARON RD	Signal			
	N/A				
	N/A				
Total Cost:		\$ 1850.00			

