


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 12450	Main Street: N_ALEXANDER_ST	Cross Street: E_9TH_ST	Location: W
ADA ID: 90EEED01FA7A	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 31.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		No	Ramp Length (in)	72.0
			No	Ramp Width (in)	35.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.1, R304.2.2, R304.5.3			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
Total Cost: \$ 3200.00			No	Painted X Walk1?	No
			N/A	X Walk 1 Direction	To SE
			N/A	X Walk 1 Width (in)	N/A
			N/A	X Walk 1 Slope (%)	2.3
			N/A	X Walk 1 X Slope (%)	3.3
			N/A	Ramp inside XWalk1?	N/A
			N/A	Road Slope (%)	4.5
			N/A	Road X Slope (%)	0.9
			N/A	Any Obstructions?	N/A
			N/A	Obstruction Type	
			N/A	Storm Grate/Utility Hazard?	N/A
			N/A	Storm Grate/Utility Type	
			N/A	Surface Condition? (G/P)	Good

