

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 15145 Main Street: DIANA\_DR Cross Street: IVERSON\_WY Location: E

ADA ID: 925582C65921 Ramp Type: Perp Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 13.75

Codes/Mitigation Info/Possible Solution

## Field Measurements/Component Compliance

Yes

Surface Condition? (G/P)

Good



Street 1 Name	DIANA DR
Stop Condition-Street 2	StopSign
Street 2 Name	N/A
Stop Condition-Street 1	N/A

/Possible Solution				Field Measurements/Component Compliance						
ŝ	Possible Solutions:			Comp	liance Description	Data	Comp	oliance Description	Data	
200	Remove & Replace Entire	Ram	ıp.	N/A	Ramp Length (in)	111.0	No	Ramp Slope (%)	9.8	
Section 1	·			Yes	Ramp Width (in)	54.0	No	Ramp XSlope (%)	2.9	
ğ				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
The Real Property lies				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
2				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
1	Surveyor Notes:			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
	N/A			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
Office Co.				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
ZIII DES				N/A	Shared Landing?	N/A				
	PROW/ADA:			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
100	R304.2.2, R304.5.3			N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
	,			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A	
1					X Walk 1 Direction	To SW		X Walk 2 Direction	N/A	
4				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
					X Walk 1 Slope (%)	0.9		X Walk 2 Slope (%)	N/A	
					X Walk 1 X Slope (%)	0.6		X Walk 2 X Slope (%)	N/A	
				N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
					Road Slope (%)	N/A	N/A	Clear Space?	N/A	
					Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
	Total Cost:	\$	1850.00		Obstruction Type			Storm Grate/Utility Type		
						N/A			N/A	





