

# Access Compliance Report


## Public Rights-of-Way

### (Curb Ramps)

|                        |                         |                            |                        |
|------------------------|-------------------------|----------------------------|------------------------|
| Intersection ID: 47441 | Main Street: POWATAN_CT | Cross Street: KALISPELL_LN | Location: NE           |
| ADA ID: 963DFDC5B109   | Ramp Type: BlendTrans1  | Initial Pass/Fail: Pass    | Overall Compliance: No |
|                        |                         | Severity Score: 0          |                        |

#### Codes/Mitigation Info/Possible Solution

#### Field Measurements/Component Compliance



Possible Solutions:

**Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.**

Surveyor Notes:

**N/A**

PROW/ADA:

**Not Found, R305.2**

Total Cost: \$ 3200.00

| Compliance | Description           | Data   | Compliance | Description                 | Data   |
|------------|-----------------------|--------|------------|-----------------------------|--------|
| N/A        | Ramp Length (in)      | 46.0   | Yes        | BlendTrans Slope (%)        | 4.3    |
| Yes        | Ramp Width (in)       | 48.0   | Yes        | BlendTrans XSlope (%)       | 1.7    |
| N/A        | Flare Type LT         | Sloped | N/A        | Flare Type RT               | Sloped |
| N/A        | Flare Slope LT (%)    | 2.0    | N/A        | Flare Slope RT (%)          | 5.7    |
| N/A        | Flare Traversable LT? | No     | N/A        | Flare Traversable RT?       | No     |
| Yes        | Landing Length (in)   | 48.0   | Yes        | DWS Provided?               | Yes    |
| Yes        | Landing Width (in)    | 48.0   | Yes        | DWS Contrast?               | Yes    |
| Yes        | Landing Slope (%)     | 0.2    | Yes        | DWS Length (in)             | 24.0   |
| Yes        | Landing X Slope (%)   | 1.4    | Yes        | DWS Full Width?             | Yes    |
| N/A        | Landing Curb? (Y/N)   | No     | No         | DWS Offset (in)             | 9.5    |
| N/A        | Shared Landing?       | No     |            |                             |        |
| Yes        | Gutter Ponding?       | No     | Yes        | Gutter Slope (%)            | 0.8    |
| Yes        | Gutter Lip Ht (in)    | 0.0    | Yes        | Gutter X Slope (%)          | 2.0    |
| N/A        | Painted X Walk1?      | No     | N/A        | Painted X Walk2?            | No     |
|            | X Walk 1 Direction    | To W   |            | X Walk 2 Direction          | To S   |
|            | X Walk 1 Width (in)   | N/A    |            | X Walk 2 Width (in)         | N/A    |
|            | X Walk 1 Slope (%)    | 0.5    |            | X Walk 2 Slope (%)          | 1.2    |
|            | X Walk 1 X Slope (%)  | 1.0    |            | X Walk 2 X Slope (%)        | 2.8    |
| N/A        | Ramp inside XWalk1?   | N/A    | N/A        | Ramp inside XWalk2?         | N/A    |
|            | Road Slope (%)        | 2.8    |            | Clear Space?                | Yes    |
|            | Road X Slope (%)      | 1.6    | N/A        | Clear Space to XWalk (in)   | N/A    |
| Yes        | Any Obstructions?     | No     | Yes        | Storm Grate/Utility Hazard? | No     |
|            | Obstruction Type      |        |            | Storm Grate/Utility Type    |        |
|            |                       | N/A    |            |                             | N/A    |
|            |                       |        | Yes        | Surface Condition? (G/P)    | Good   |
|            |                       |        | No         | Curb Slope (%)              | 11.6   |

Street 1 Name KALISPELL LN  
 Stop Condition-Street 1 None  
 Street 2 Name POWATAN CT  
 Stop Condition-Street 2 StopSign

